### OVE Austrian Electrotechnical Association

Eschenbachgasse 9 | 1010 Wien | Austria

ZVR: 327279890 | www.ove.at

**OVE Testing and Certification** 

Kahlenberger Str. 2A | 1190 Wien | Austria T +43 1 370 58 06 | certification@ove.at

ENEC Certification Body registered under ID # 11.



Validity of ENEC Licences can be checked at www.enec.com

# LICENCE

to use the European Mark



251-196 Licence No.: Date of issue: Wien, 2018 10 24 Rev. No.: 02 Wien, 2020 09 01

OVE the Austrian Electrotechnical Association as signatory to the "Agreement on the use of a commonly agreed Mark of Conformity for certain electrical equipment complying with European Standards" hereby grants the right to label the products mentioned hereunder and listed in the Annex with the Mark(s) shown above to the following company

Licenceholder: **Zumtobel Lighting GmbH** 

> Schweizer Str. 30 6850 Dornbirn

Austria

Product: **Luminaires with limited surface temperatures** 

Trade Mark: THORN

Aquaforce 3 Series/Type:

Basis for this given right is the conformity of the products with the requirements of the relevant Standard(s) as listed in the Annex and the fulfilment of articles 8 and 9 of the ENEC-Agreement by the manufacturer. This licence refers to the tested specimen and to all products manufactured strictly identical to the submitted one.

This licence has been issued under the presumption and conditional on the fact that the licensee holds all necessary legal rights with regard to the product presented for testing and certification.

Österreichischer Verband für Elektrotechnik

Head of Testing and Certification

Digitally signed by W. Martin Email=w.martin@ove.at

Dipl.-Ing. W. Martin

## **OVE Testing and Certification**

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under www.bmdw.gv.at/akkreditierung.





Date: 2020 09 01 Page 2 of 5

Hersteller **Thorn Lighting Ltd** Manufacturer Durhamgate, Spennymoor, **County Durham DL16 6HL United Kingdom** Fertigungsstätte(n) **Zumtobel Lighting GmbH** Schweizer Str. 30 Factory location(s) 6850 Dornbirn **Austria** Series AQFPRO . LED..., Typenbezeichnung Type reference see page 5 Prüfbericht TR-251-0114-02 ECS Test Report Nationale Bestimmung(en) OVE EN 60598-1:2018-11-01 National Standard(s) ÖVE/ÖNORM EN 60598-2-24:2014-05-01 Europanorm(en) EN 60598-1:2015 + A1:2018 European Standard(s) EN 60598-2-24:2013 Ersatz für Zertifikat 251-196 Rev. 01 dated 2019 10 28 Superseded licence Items modified are marked with an asterisk (\*) Anmerkung(en) CTF Stage 2 Remark(s)







Date: 2020 09 01

Page 3 of 5

Nennspannung Rated voltage 220-240 V; 0/50/60 Hz

Anzahl und Leistung der Lampen Rated wattage and number of lamps 2/3 x LEM S40...

Lampentyp(en)
Lamp identification

LED modules (ILCOS: DSL)

Schutzgrad

IP66

CI. I

Degree of protection

Netzanschluss

Supply connection

Screwless terminals

Befestigungsfläche

Supporting surface

Normally flammable surface

Schutzklasse Class of protection

of a rate of a se

Beschreibung des Aufbaus Description of construction

Luminaires with limited surface temperature for wall and ceiling mounting. The luminaire has a special drip-edge-effect. Two different optics, Middle Beam or Wide Beam are available. The LED modules and the ECG are fixed

on the light engine with screws.

Zusatzinformation
 Additional information

Light source classified as RG0 according to

EN 62471:2008.





Date: 2020 09 01 Page 4 of 5

	Bauteil	Code	Hersteller	Typenbezeichnung	Konformitätszeichen
	Component			Type Reference	Mark(s) of conformity
*	LED module	<b>A</b> *	Zumtobel	LEM \$40	ÖVE
	LED control gear	В	Tridonic	LCA 50W	ENEC 11
		В	Tridonic	LCA 75W	ENEC 11
*		В	Thorn	LC 35W	ENEC 18
*		В	Thorn	LC 54W	ENEC 18
*		В	Thorn	LC 68W	ENEC 18
*		В	Tridonic	LC 35W	ENEC 11
*		В	Tridonic	LC 54W	ENEC 11
Î		В	Tridonic	LC 67W	ENEC 11
		В	Philips	Xitanium 36W	ENEC 05
		В	Philips	Xitanium 60W	ENEC 05
		В	Philips	Xitanium 75W	ENEC 05
		B B	Osram Osram	OTi 35 OTi 60	VDE VDE
		В	Osram	OTi 75	VDE
		В	Osram	OTi 90	VDE
		Ь	Ostalli	011 90	VDE
	Sensor	Α	Tridonic	smartSWITCH HF; 220-240V; 50Hz; Tc 70°C	ENEC 05
*	Terminal	Α	Electro Terminal	SLK 3; ACDC 450 V; 24A; 0,5-2,5 mm²; T110	ENEC 11
	Connector	Α	Stucchi	3701, 3702; 400V; 16A; T110	IMQ
	Wiring	Α	Leoni	Ecosense S05G-U; 300/500 V; 0,5 mm <sup>2</sup> ; 110°C	BBJ
*		Α	Leoni	Ecosense S07G-U; 450/750 V; 1,5 / 2,5 mm²; 110°C	BBJ
*	Enclosure	С	Zumtobel	PMMA, PC;	Checked within appliance
	A The component is replaceable with another one, also certified, with equivalent characteristics.  A* The component is replaceable with another one, according to ETF5-OSM-LUM/DSH 2057.				


- The component is replaceable with another one, according to ETF5-OSM-LUM/DSH 2057.
- В The component is replaceable if authorised by the test house.
- С Integrated component tested together with the appliance.
- Ď Alternative component.





Date: 2020 09 01 Page 5 of 5

## Typecode:



Accessories: AQFPRO FIX/CH KIT

AQFPRO MCA KIT

MOUNTING SET AQUAFORCE PRO DIFUSER AQUAFORCE PRO \* \* \*\*

HLD TW AQFPRO

HOUSING AQUAFORCE PRO \*



